

Page 1 of 2

Certificate No: LR2040331TA-01 Issue Date: 04/03/2022 Expiry Date: 09/11/2025

Type Approval Certificate

This is to certify that the undernoted product(s) has/have been tested with satisfactory results in accordance with the relevant requirements of the Lloyd's Register Type Approval System.

Manufacturer STS Sensor Technik Sirnach AG

Address Rütihofstraße 8, Sirnach, 8370, Switzerland

Place of Production STS Sensor Technik Sirnach AG

Rütihofstraße 8, Sirnach, 8370, Switzerland

Type Transmitters/Transducers

Description Programmable Pressure Transmitter PTM/Ex (Intrinsically Safe)

Programmable Submersible Level Transmitter PTM/N/Ex (Intrinsically Safe)

For detailed description, pls. refer to appendix.

Trade Name PTM/Ex, PTM/N/Ex

Application Marine, offshore and industrial applications for use in environmental

categories ENV1, ENV2 and ENV4 as defined in Lloyd's Register's Type Approval

System, Test Specification Number 1 - 2018.

Specified Standard Manufacturer's specification

IACS requirements E10(1991/Rev.8: Feb 2021)

Ratings Pressure types: gauge, absolute or sealed

Pressure range: 0 ... 1000 bar / 1 ... 250 mH2O (submersible type)

Power supply: 24 VDC

Thorsten Wolff

Senior Specialist to Lloyd's Register EMEA A member of the Lloyd's Register group

71 Fenchurch Street, London, EC3M 4BS, United Kingdom

Lloyd's Register Group Limited, its affiliates and subsidiaries and their respective officers, employees or agents are, individually and collectively, referred to in this clause as 'Lloyd's Register'. Lloyd's Register assumes no responsibility and shall not be liable to any person for any loss, damage or expense caused by reliance on the information or advice in this document or howsoever provided, unless that person has signed a contract with the relevant Lloyd's Register entity for the provision of this information or advice and in that case any responsibility or liability is exclusively on the terms and conditions set out in that contract.



Page 2 of 2

Certificate No: LR2040331TA-01 Issue Date: 04/03/2022 Expiry Date: 09/11/2025

Type Approval Certificate

Output signal: 4 ... 20 mA

Degree of protection: IP 65 (DIN connector), IP 67, IP 68 (submersible type)

Additional Tests Dry heat test (+70 °C / 2 h)

Low temperature test (-25 °C / 2 h)

Other Conditions Specific Conditions of Use as stated in applicable Ex-certificates and the

conditions of the LR Rules and Regulations of Classification of Ships Part 6, Chapter 2 shall be observed when installed in hazardous areas. The Ex-

certification does not form part of this certificate.

This certificate is not valid for equipment, the design, ratings or operating parameters of which have been varied from the specimen tested. The manufacturer should notify Lloyd's Register EMEA of any modification or changes to the equipment in order to obtain a valid Certificate.

Previous Version: This certificate supersedes certificate number LR2040331TA issued on

10.11.2020 which is hereby cancelled.

The Design Appraisal Document HTS/ETS 42315-22/HN/TW and its supplementary Type Approval Terms and Conditions form part of this Certificate.

71 Fenchurch Street, London, EC3M 4BS, United Kingdom

Lloyd's Register Group Limited, its affiliates and subsidiaries and their respective officers, employees or agents are, individually and collectively, referred to in this clause as 'Lloyd's Register'. Lloyd's Register assumes no responsibility and shall not be liable to any person for any loss, damage or expense caused by reliance on the information or advice in this document or howsoever provided, unless that person has signed a contract with the relevant Lloyd's Register entity for the provision of this information or advice and in that case any responsibility or liability is exclusively on the terms and conditions set out in that contract.



Page 1 of 2

Certificate No: LR2040331TA-01 Issue Date: 04/03/2022

Expiry Date: 09/11/2025

Appendix

DESCRIPTION

Programmable Pressure Transmitter PTM/Ex (Intrinsically Safe)
Programmable Submersible Level Transmitter PTM/N/Ex (Intrinsically Safe)

Firmware Version: V2.0x

PTM/Ex47 0234567890

①	B	•	Course
1	Pressure type	1	Gauge
		2	Absolute (vacuum)
<u> </u>		3	Sealed gauge
2	Pressure measuring range		0.1 bar 600 bar
		XX	0 1000 bar
3	Process connection	00	G 1/4 F
		10	1/4 NPT M
		19	1/2 NPT M
		11	G 1/4 M
		21	G 1/4 M, flush diaphragm
		12	G 1/4 M, Manometer DIN-16288
		13	G 1/2 M
		41	G 1/2 M, Hastelloy C-276
		14	G 1/2 M, frontal diaphragm
		37	G 1/2 M, frontal diaphragm Hastelloy C-276
		15	G 1/2 M, flush diaphragm
		16	G 1/2 M, Manometer DIN-16288
		17	G 1/2 M, with bore Ø 14 mm
		99	Customized
4	Electrical connection	01	DIN-43650 plastic PA, with metal threaded part, demountable, IP 65
		03	M16 (Binder 723), 5 pins, IP 67
		04	M16 (Binder 723), 7 pins, demountable, IP 67
		80	MIL C26482, 10-6, IP 40
		07	M12x1, 4 pins
		17	PUR cable, blue, IP 67
		22	FEP cable, blue, IP 67
		36	PUR cable, blue, with submersible back end, IP 68
		99	Customized
(5)	Output signal	05	4 20 mA
		08	4 20 mA with overvoltage protection
6	Accuracy	1	≤±0.25% FS (≤ 500 mbar / > 600 bar)
	j	2	≤±0.1% FS (> 500 mbar 600 bar)
7	Temperature range	0	T6 (Ta: -25 55 °C) 0 70 °C compensated
		1	T4 (Ta: -25 85 °C) -25 85 °C compensated
		2	T3 (Ta: -25 85 °C) -25 85 °C compensated
8	Option 1	A	Throttle
	- p	G	Special oil filling: Anderol Food (for food applications)
		Q	Special oil filling: PAO4 (silicone free)
9	Option 2	٣	nil
10	Option 3	Е	Active compensated (≥ 100 mbar ≤ 100 bar)
		K	Version titanium
		U	Seals: Viton (standard)
		S	Seals: EPDM
		T	Seals: Kalrez
		Н	Seals: NBR (ACS)
		п	Jeans, INDIX (ACJ)

Lloyd's Register Group Limited, its affiliates and subsidiaries and their respective officers, employees or agents are, individually and collectively, referred to in this clause as 'Lloyd's Register'. Lloyd's Register assumes no responsibility and shall not be liable to any person for any loss, damage or expense caused by reliance on the information or advice in this document or howsoever provided, unless that person has signed a contract with the relevant Lloyd's Register entity for the provision of this information or advice and in that case any responsibility or liability is exclusively on the terms and conditions set out in that contract.

R R R

> R R R R

> > <u>え</u>えっ

R

R



Page 2 of 2

Certificate No: LR2040331TA-01

Issue Date: 04/03/2022 Expiry Date: 09/11/2025

DESCRIPTION (continued)

PTM/N/Ex 48 0234567890

①	D	-	Comme
1	Pressure type	1	Gauge
		2	Absolute (vacuum)
2	Pressure measuring range	XX	1 250 mH2O)
3	Process connection	55	Closed
		56	Open
		11	G 1/4 M
		13	G 1/2 M
		99	Customized connections available
4	Electrical connection	17	PUR cable, blue, IP 68
		22	FEP cable, blue, IP 68
		07	Connectable version, IP 68, M12x1
(5)	Output signal	05	4 20 mA
		80	4 20 mA with surge protection
6	Accuracy	1	≤±0.25 % FS (≤5 mH2O)
		2	≤±0.1 % FS (> 5 mH2O)
7	Temperature range	3	T6 (Ta: -5 50 °C) -5 50 °C compensated
		5	T4 (Ta: -5 80 °C) -5 80 °C compensated
8	Option 1	G	Special oil filling: Anderol Food (for food applications)
9	Option 2		nil
10	Option 3	В	Ballast weight 1.4435
		Ε	Active compensated
		K	Version titanium (without ballast weight)
		U	Seals: Viton (standard)
		S	Seals: EPDM
		Т	Seals: Kalrez (Level)
		Н	Seals: NBR
		Z	Humidity filter element for gauge version (only for PUR cable)

Lloyd's Register Group Limited, its affiliates and subsidiaries and their respective officers, employees or agents are, individually and collectively, referred to in this clause as 'Lloyd's Register'. Lloyd's Register assumes no responsibility and shall not be liable to any person for any loss, damage or expense caused by reliance on the information or advice in this document or howsoever provided, unless that person has signed a contract with the relevant Lloyd's Register entity for the provision of this information or advice and in that case any responsibility or liability is exclusively on the terms and conditions set out in that contract.

IR IR

> R R R

R R

R R

R

R