

Page 1 of 2 Certificate No: LR2035641TA-01 Issue Date: 01/03/2022 Expiry Date: 13/12/2025

Type Approval Certificate

This is to certify that the undernoted product(s) has/have been tested with satisfactory results in accordance with the relevant requirements of the Lloyd's Register Type Approval System.

Manufacturer	STS Sensor Technik Sirnach AG
Address	Rütihofstraße 8, Sirnach, 8370, Switzerland
Place of Production	STS Sensor Technik Sirnach AG
	Rütihofstraße 8, Sirnach, 8370, Switzerland
Туре	Transmitters/Transducers
Description	Analog Pressure Transmitter ATM 23 Analog Level Transmitter ATM/N 24 Analog Pressure Transmitter ATM/Ex 33 Analog Level Transmitter ATM/N/Ex 34
	For detailed description, pls. refer to appendix.
Trade Name	ATM, ATM/Ex, ATM/N, ATM/N/Ex
Application	Marine, offshore and industrial applications for use in environmental categories ENV1, ENV2 and ENV4 as defined in Lloyd's Register's Type Approval System, Test Specification Number 1 - 2018.
Specified Standard	Manufacturer's specification IACS requirements E10 (1991/ Rev.8: Feb 2021)

Thorsten Wolff

Senior Specialist to Lloyd's Register EMEA A member of the Lloyd's Register group

71 Fenchurch Street, London, EC3M 4BS, United Kingdom



Page 2 of 2 Certificate No: LR2035641TA-01 Issue Date: 01/03/2022 Expiry Date: 13/12/2025

Type Approval Certificate

Ratings	Pressure types: Pressure range: Power supply: Output signals: Degree of protection:	gauge, absolute or sealed 00.05 bar up to 01000 bar 24 VDC 020 mA, 420 mA, 05 VDC, 010 VDC IP 65, IP 67, IP 68 (depending on electrical connection)		
Other Conditions	Specific Conditions of Use as stated in applicable Ex-certificates and the conditions of the LR Rules and Regulations of Classification of Ships, Part 6, Chapter 2 shall be observed when installed in hazardous areas. The Excertification does not form part of this certificate.			

This certificate is not valid for equipment, the design, ratings or operating parameters of which have been varied from the specimen tested. The manufacturer should notify Lloyd's Register EMEA of any modification or changes to the equipment in order to obtain a valid Certificate.

Previous Version: This certificate supersedes certificate number LR2035641TA issued on 14.12.2020 which is hereby cancelled

The Design Appraisal Document HTS/ETS Out-ID 42216-22/HN/TW and its supplementary Type Approval Terms and Conditions form part of this Certificate.

71 Fenchurch Street, London, EC3M 4BS, United Kingdom



Page1 of 4Certificate No:LR20356Issue Date:01/03/2Expiry Date:13/12/2

LR2035641TA-01 01/03/2022 13/12/2025

Appendix

DESCRIPTION

Analog Pressure Transmitter ATM 23... Analog Level Transmitter ATM/N 24... Analog Pressure Transmitter ATM/Ex 33... Analog Level Transmitter ATM/N/Ex 34...

ATM 23 1 2 3 4 5 6 7 8 9 0

			-
1	Pressure type	1	Gauge
		2	Absolute (vacuum)
		3	Sealed gauge
2	Pressure measuring range		0 0.05 bar
		XX	0 1000 bar
3	Process connection	00	G 1/4 F
		10	1/4 NPT M
		19	1/2 NPT M
		11	G 1/4 M
		21	G 1/4 M, flush diaphragm
		12	G 1/4 M, Manometer DIN-16288
		13	G 1/2 M
		41	G 1/2 M, Hastelloy C-276
		14	G 1/2 M, frontal diaphragm
		37	G 1/2 M, frontal diaphragm Hastelloy C-276
		15	G 1/2 M, flush diaphragm
		16	G 1/2 M, Manometer DIN-16288
		17	G 1/2 M, with bore Ø 14 mm
		99	Customized
4	Electrical connection	01	DIN-43650 plastic PA, with metal threaded part, demountable IP 65
		03	M16 (Binder 723), 5 pins, IP 67
		43	M16 (Binder 723), 5 pins, demountable, IP 67
		06	MIL C26482, 10-6, IP 40
		07	M12x1, 4 pins
		13	PE cable, black, IP 67
		15	PUR cable, black, IP 67
		24	PUR cable, black, with submersible back end IP 68
		21	FEP cable, black
		99	Customized
5	Output signal	05	4 20 mA
_	1 0	00	0 20 mA
		46	05VDC
		47	0 10 VDC
		08	4 20 mA with surge protection
		49	0 10 VDC with surge protection
		50	0 5 VDC with surge protection
6	Accuracy	0	$\leq 600 \text{ bar} \leq \pm 0.5 \% \text{ FS}$
		1	$\leq 600 \text{ bar} \leq \pm 0.25 \% \text{ FS}$
		2	$\leq 600 \text{ bar} \leq \pm 0.1 \% \text{ FS}$
		5	$> 600 \text{ bar} \le \pm 1\% \text{ FS}$
		0	$> 600 \text{ bar} \le \pm 0.5 \% \text{ FS}$
		1	$> 600 \text{ bar} \le \pm 0.5 \% \text{ FS}$
		T	~ 000 Dal > I 0.23 % FS



 Page
 2 of 4

 Certificate No:
 LR2035641TA-01

 Issue Date:
 01/03/2022

 Expiry Date:
 13/12/2025

DESCRIPTION (continued)

ATM 23 0 2 3 4 5 6 7 8 9 0

\bigcirc	Temperature range	0	0 70 °C compensated
		7	25 100 °C compensated
		1	-25 85 °C compensated
		2	-25 85 °C compensated with cooling fins
		6	20 100 °C compensated with cooling fins
		3	-40 100 °C compensated
		4	-40 100 °C compensated with cooling fins
8	Option 1	Α	Throttle
		G	Special oil filling: Anderol Food (for food applications)
		J	Special oil filling: AS 100
		Q	Special oil filling: PAO4 (silicone free)
		Ν	Pressure connection elastomer free
		V	Pressure connection welded
9	Option 2	С	Electronics packed in gel: Gauge pressure
		D	Electronics packed in gel: Absolute pressure
1	Option 3	К	Version titanium
		U	Seals: Viton (standard)
		S	Seals: EPDM
		Т	Seals: Kalrez (Industry)
		Н	Seals: NBR (ACS)

ATM/N240234567890

1	Pressure type	1	Gauge
		2	Absolute (vacuum)
2	Pressure measuring range	XX	0 0.5 mH2O
		XX	0 250 mH2O
3	Process connection	55	Closed
		59	Closed, 1.4435
		56	Open
		11	G 1/4 M
		13	G 1/2 M
		99	Customized
4	Electrical connection	13	PE cable, IP 68, black
		15	PUR cable, IP 68, black
		21	FEP cable, IP 68, black
		14	PVC cable, blue, IP 68
		07	Connectable version, IP 68, M12x1
		99	Customized
5	Output signal	46	0 5 VDC
		47	0 10 VDC
		00	0 20 mA
		05	4 20 mA
		08	4 20 mA with overvoltage protection
		49	0 10 VDC with overvoltage protection
		50	0 5 VDC with overvoltage protection
		99	Customized
6	Accuracy	0	≤±0.5%FS
		1	≤±0.25%FS
		2	≤±0.1%FS
Ø	Temperature range	4	-5 50 °C compensated
		5	-5 80 °C compensated
8	Option 1		nil
9	Option 2	С	Electronics packed in gel: Gauge pressure
		D	Electronics packed in gel: Absolute pressure



 Page
 3 of 4

 Certificate No:
 LR2035641TA-01

 Issue Date:
 01/03/2022

 Expiry Date:
 13/12/2025

DESCRIPTION (continued)

ATM/N240234567890

10	Option 3 B	Ballast weight 1.4435
	К	Version titanium (without ballast weight)
	U	Seals: Viton (standard)
	S	Seals: EPDM
	т	Seals: Kalrez (Level)
	н	Seals: NBR (7)
	Z	Humidity filter element for gauge versions (only for PUR and PE
		cable)

ATM/Ex331234567890

① Pressure type 1 Gauge 2 Absolute (vacuum) 3 Sealed gauge ② Pressure measuring range XX 0 0.05 bar XX 0 1000 bar ③ Process connection 00 G 1/4 F 10 1/4 NPT M 19 1/2 NPT M 11 G 1/4 H 21 G 1/4 flush diaphragm 12 G 1/4 M, manometer DIN 16288		ssure type	1	Gauge
3 Sealed gauge (2) Pressure measuring range XX 0 0.05 bar (3) Process connection 00 G1/4 F 10 1/4 NPT M 19 1/2 NPT M 11 G 1/4 H G 1/4 flush diaphragm 12 G 1/4 flush diaphragm 12 G 1/4 M, manometer DIN 16288	 Proc 			
② Pressure measuring range XX 0 0.05 bar 3 Process connection 00 G 1/4 F 10 1/4 NPT M 19 1/2 NPT M 11 G 1/4 H 21 G 1/4 flush diaphragm 12 G 1/4 M, manometer DIN 16288	2 Proc		2	Absolute (vacuum)
XX 0 1000 bar ③ Process connection 00 G 1/4 F 10 1/4 NPT M 19 1/2 NPT M 11 G 1/4 M 21 G 1/4 flush diaphragm 12 G 1/4 flush diaphragm 12 G 1/4 M, manometer DIN 16288	(2) Proc		3	Sealed gauge
③ Process connection 00 G 1/4 F 10 1/4 NPT M 19 1/2 NPT M 11 G 1/4 M 21 G 1/4 flush diaphragm 12 G 1/4 M, manometer DIN 16288		ssure measuring range	XX	0 0.05 bar
10 1/4 NPT M 19 1/2 NPT M 11 G 1/4 M 21 G 1/4 flush diaphragm 12 G 1/4 M, manometer DIN 16288			XX	0 1000 bar
19 1/2 NPT M 11 G 1/4 M 21 G 1/4 flush diaphragm 12 G 1/4 M, manometer DIN 16288	③ Proc	cess connection	00	G 1/4 F
11 G 1/4 M 21 G 1/4 flush diaphragm 12 G 1/4 M, manometer DIN 16288			10	1/4 NPT M
21G 1/4 flush diaphragm12G 1/4 M, manometer DIN 16288			19	1/2 NPT M
12 G 1/4 M, manometer DIN 16288			11	G 1/4 M
			21	G 1/4 flush diaphragm
			12	G 1/4 M, manometer DIN 16288
13 G 1/2 M			13	G 1/2 M
98 G 1/2 M, Hastelloy C-276 98			98	G 1/2 M, Hastelloy C-276 98
14 G 1/2 M, frontal diaphragm			14	
37 G 1/2 male, frontal diaphragm Hastelloy C-276			37	G 1/2 male, frontal diaphragm Hastelloy C-276
15 G 1/2 M, flush diaphragm			15	G 1/2 M, flush diaphragm
16 G 1/2 M, manometer DIN-16288			16	G 1/2 M, manometer DIN-16288
17 G 1/2 male with bore Ø 14 mm			17	G 1/2 male with bore Ø 14 mm
99 Customized			99	Customized
Electrical connection 01 DIN-43650 with metal threaded part, demountable, IP 65	④ Elec	ctrical connection	01	DIN-43650 with metal threaded part, demountable, IP 65
03 M16 (Binder 723), 5 pins, IP 67			03	M16 (Binder 723), 5 pins, IP 67
43 M16 (Binder 723), 5 pins, demountable, IP 67			43	M16 (Binder 723), 5 pins, demountable, IP 67
06 MIL C26482, 10-6, IP 40			06	MIL C26482, 10-6, IP 40
07 M12x1, 4 pins			07	M12x1, 4 pins
17 PUR cable, blue, IP 67			17	PUR cable, blue, IP 67
36 PUR cable, blue, with submersible back end IP 68			36	PUR cable, blue, with submersible back end IP 68
22 FEP cable, blue, IP 67			22	FEP cable, blue, IP 67
99 Customized			99	Customized
⑤ Output signal 05 4 20 mA	⑤ Outp	put signal	05	4 20 mA
08 4 20 mA with surge protection			08	4 20 mA with surge protection
	6 Accu	uracy	0	≤ 600 bar ≤ ± 0.5 % FS
$1 \leq 600 \text{ bar} \leq \pm 0.25 \% \text{ FS}$			1	≤ 600 bar ≤ ± 0.25 % FS
2 ≤600 bar≤±0.1% FS			2	≤600 bar≤±0.1%FS
5 >600 bar≤±1% FS			5	> 600 bar ≤ ± 1 % FS
0 > 600 bar ≤ ± 0.5 % FS			0	> 600 bar ≤ ± 0.5 % FS
1 >600 bar ≤± 0.25 % FS			1	> 600 bar ≤ ± 0.25 % FS
⑦ Temperature range 0 T6 (Ta: -25 55 °C) 0 70 °C compensated	⑦ Tem	nperature range	0	T6 (Ta: -25 55 °C) 0 70 °C compensated
1 T4 (Ta: -25 85 °C) -25 85 °C compensated		-	1	T4 (Ta: -25 85 °C) -25 85 °C compensated
2 T3 (Ta: -25 85 °C) -25 85 °C compensated			2	T3 (Ta: -25 85 °C) -25 85 °C compensated



Page	4 of 4
Certificate No:	LR2035641TA-01
Issue Date:	01/03/2022
Expiry Date:	13/12/2025

DESCRIPTION (continued)

ATM/Ex330234567890

8	Option 1	Α	Throttle
		G	Special oil filling: Anderol Food (for food applications)
		J	Special oil filling: AS 100
		Q	Special oil filling: PAO4 (silicone free)
		Ν	Pressure connection elastomer free
		V	Pressure connection welded
9	Option 2		nil
10	Option 3	Κ	Version titanium
		U	Seals: Viton (standard)
		S	Seals: EPDM
		Т	Seals: Kalrez (Industry)

ATM/N/Ex 34 1234567890

1	Pressure type	1	Gauge
_		2	Absolute (vacuum)
2	Pressure measuring range	XX	0 0.5 mH2O
		XX	0 250 mH2O
3	Process connection	55	Closed
		56	Open
		11	G 1/4 M
		13	G 1/2 M
		99	Customized connections available
4	Electrical connection	07	Connectable version, IP 68
		17	PUR cable, blue, IP 68
		22	FEP cable, blue, IP 68
		99	Customized
(5)	Output signal	05	4 20 mA
		08	4 20 mA with surge protection
6	Accuracy	0	≤±0.5%FS
		1	≤±0.25%FS
		2	≤±0.1%FS
\bigcirc	Temperature range	3	T6 (Ta: -5 50 °C) -5 50 °C compensated
		5	T4 (Ta: -5 80 °C) -5 80 °C compensated
8	Option 1		nil
9	Option 2		nil
10	Option 3	В	Ballast weight 1.4435
		U	Seals: Viton (standard)
		S	Seals: EPDM
		Т	Seals: Kalrez (Level)
		К	Version titanium (without ballast weight)
		Ζ	Humidity filter element for gauge versions (only for PUR cable)